



MISSISSIPPI STATE DEPARTMENT OF HEALTH

REPORT OF INSPECTION OF DRINKING WATER SUPPLY

PWS: 0640014 Class: C

An inspection of the SMITHS CROSSING WATER ASSN water supply in SIMPSON county was made on 10/29/2025. Present at the time of inspection was CHRISTOPHER S WOMACK, OPERATOR; WRITER. Official JOHN KILPATRICK Address PO BOX 956 MAGEE MS 39111 W.W. Operator CHRISTOPHER S WOMACK Address 613 GOLF COURSE RD MENDENHALL MS 39114 No. Connections 1652 No. Meters Population Served 4367 Field Chemical Analysis: pH C12(free) C12(total) H2S N/A Iron Fluoride Point of Sampling DISTRIBUTION Water Rates This inspection included a sanitary survey for compliance with the Ground Water Rule.

COMMENTS

Technical: 51/51 Managerial: 33/33 Financial: 16/16

OVERALL CAPACITY RATING: 100 / 100

1. This inspection serves as the Sanitary Survey as required under the Ground Water Rule. The following aspects of the water system were evaluated: source, treatment, distribution system, finished water storage, pump/pump facilities/controls, monitoring/reporting/data verification, water system management/operation, and operator compliance. No significant deficiencies were observed during the survey.
2. The target pH for this system is 9.0 as long as soda ash is used for corrosion control. At the time of the inspection, the chemical analysis of the finished water was as follows:

Plant 1: pH = 8.8
 free chlorine = 1.7 mg/L
 Plant 2: pH = 8.8
 free chlorine = 1.8 mg/L
 Plant 5: pH = 8.7
 free chlorine = 1.7 mg/L
 Plant 6: pH = 8.9
 free chlorine = 1.5 mg/L
 Plant 3: pH = 8.8
 free chlorine = 1.8 mg/L

The system should maintain the pH between +/- 0.5 of the target at all times.

3. The system has entered into a tank maintenance contract since the last inspection.
4. The system has received an ARPA grant and is in the process of drilling a new well at Plant 3.
5. The system has temporarily stopped feeding fluoride due to the rising cost and product unavailability.
6. As a reminder, the system should have a completed, working Asset Management Plan for review during the annual inspection.
7. Whenever system pressure is lost, even for brief periods of time, contaminants may be introduced to the system through back-flow or back-siphonage. When this occurs, system officials should notify all customers in the affected area to boil their drinking water until clear bacteriological samples have been obtained.
8. All dead-end water lines should be flushed on a routine schedule to clear the lines of sediment and stagnant water.
9. When repairs are made on the water distribution system, all lines affected should be properly chlorinated and flushed before they are placed back in service.
10. Records that are required in accordance with the Safe Drinking Water Act include:
 - Bacti Site Plan with map & sample results - 5 yrs.
 - Other water quality analysis - 10 yrs.
(THMs, HAA5s, nitrates, inorganics, VOCs, etc.)
 - Lead and Copper Site Plan & sample results - 12 yrs.
 - Inspection Reports - 10 yrs.
 - Annual Report - 3 yrs.
 - Operator's Logbook - 5 yrs.
 - Actions taken by the system to correct violations - 3 yrs.
 - Records concerning a variance or exemption - 5 yrs.
 - All other MSDH correspondence - 3 yrs.

Completed by Colleen Cook on 11/04/2025.

Reviewed by Wendy Ferrill, P.E. on 11/04/2025.

If you have any questions, please call (601) 576-7518.

pc:

JOHN KILPATRICK, OFFICIAL
CHRISTOPHER S WOMACK, OPERATOR



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Bureau of Public Water Supply

FY 2026 Public Water System Capacity Assessment Form

Standard Form

PWS ID#	PUBLIC WATER SYSTEM
0640014	SMITHS CROSSING WATER ASSN
SURVEY DATE	COUNTY
10-29-2025	SIMPSON
CONNECTIONS	POPULATION
1652	4367
CLASS	CERTIFIED WATERWORKS OPERATOR
C	CHRISTOPHER S WOMACK



Technical

51/51

Managerial

33/33

Financial

16/16

Technical Capacity Assessment

51 of 51 points

T1	Does the water system have any significant deficiencies?	Points
	<input type="radio"/> Y <input checked="" type="radio"/> N	7/7
T2	Was the water treatment process functioning properly?	Points
	<input type="radio"/> Y <input type="radio"/> N	4/4
T3	Was needed water system equipment in place and functioning properly at the time of survey?	Points
	<input type="radio"/> Y <input type="radio"/> N	3/3
T4	Were records available to the RE clearly showing that all water storage tanks have been inspected and cleaned or painted (if needed) within the past 5 years?	Points
	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> NA	3/3
T5	Was the certified waterworks operator or his/her authorized rep present for survey?	Points
	<input type="radio"/> Y <input type="radio"/> N	3/3
T6	Was PWS Operations record up to date and properly maintained?	Points
	<input type="radio"/> Y <input type="radio"/> N	3/3
T7	Was the water system properly maintained at the time of survey?	Points
	<input type="radio"/> Y <input type="radio"/> N	3/3
T8	Does the system have adequate capability for testing the water quality of the system and could operator personnel perform all water quality tests required to properly operate this water system?	Points
	<input type="radio"/> Y <input type="radio"/> N	2/2
T9	Does water system routinely track water loss and were acceptable records available for review?	Points
	<input type="radio"/> Y <input type="radio"/> N	3/3

T10	Is the water system overloaded? Cannot exceed MSDH design capacity, consecutive systems overloaded if supplier overloaded or based on hydraulic calculations or pressure recording.	Points 3/3
	<input type="radio"/> Y <input checked="" type="radio"/> N	
T11	Was there any indication that the water system is/has been experiencing low pressure in any part(s) of the distribution system?	Points 3/3
	<input type="radio"/> Y <input checked="" type="radio"/> N	
T12	Are well pumping tests performed routinely?	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> NA	
T13	Does the water system have the ability to provide water during power outages?	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N	
T14	Does the water system have a usable backup source of water?	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N	
T15	For Groundwater systems – can the water system meet maximum daily demands with the largest producing source/treatment facility out of service? OR For Surface Water systems – Can the water system meet maximum daily demands based on 1 in 50-year drought calculations or the extreme drought of record?	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> NA	
T16	Does the system have a functioning control system for facility operations? (SCADA, Automatic Controls, etc.)	Points 2/2
	<input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> NA	

Managerial Capacity Assessment

33 of 33 points

M1	Does the PWS maintain or can the system access, via the PWS Portal, all SDWA required records? (Physical records in logical and orderly manner?)	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N	
M2	Have acceptable written policies and procedures for operating this water system been formally adopted and available for review?	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N	
M3	Have all Board Members (in office more than 12 months) completed Board Member Training?	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> NA	
M4	Does the Board meet monthly and were minutes of Board meetings available for review?	Points 2/2
	<input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> NA	
M5	Has the water system had any SDWA violations since the last Capacity Assessment?	Points 6/6
	<input type="radio"/> Y <input checked="" type="radio"/> N	
M6	Has the water system developed or is in the process of developing its asset management plan to support its long-range improvements plan and were these plans available for review during the survey?	Points 3/3
	<input checked="" type="radio"/> Y <input type="radio"/> N	
M7	Does the water system have an effective cross connection program in compliance with MSDH regulations?	Points 2/2
	<input checked="" type="radio"/> Y <input type="radio"/> N	

M8	Were copies of the MSDH approved sample site plans (RTCR, LCR, and DPB) available for review? Do results show site plans are being followed?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	3/3
M9	Does the system keep records of all customer complaints?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2
M10	Does the system have an adequate backup plan for staffing to ensure that vital operational action are covered?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2
M11	Does the System have a up to date Security Vulnerability Analysis or Risk and Resilience Assessment in place and available for review?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2
M12	Does the System have an up to date Emergency Response Plan available for review at the time of inspection?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2

Financial Capacity Assessment

16 of 16 points

F1	Has the water system raised water rates in the past 3 years?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	3/3
F2	Has the water system performed a rate study within the past 5 years ?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2
F3	If the rate study was performed, did the system act upon its recommendations?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> NA	2/2
F4	Is the water system following an official cut-off policy?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	3/3
F5	Was a copy of system's adopted annual budget available for review and does financial accounting system clearly and accurately track receipts and expenditures?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2
F6	Was the latest financial report/audit report available for review?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2
F7	Does the latest report show that receipts exceed expenditures? Excluding out of pocket for major improvements or for Municipal govts - Are the water and sewer fund accounts separate from other accounts?	Points
	<input checked="" type="radio"/> Y <input type="radio"/> N	2/2

Completed by Colleen Cook on
11/04/2025

Reviewed by Wendy Ferrill, P.E. on
11/04/2025

**MISSISSIPPI DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
DESIGN CAPACITY SHEET**

System: **SMITHS CROSSING WATER ASSN**
ID: **0640014** Class: C County: **SIMPSON**

Date Completed: **11/04/2025**
Connections - Actual: **1652** Equivalent: **1652**
Design Capacity: **3966** Percent Design Capacity: **1652/3966 = 41.7%**

MAIN SYSTEM (served by plants # 1,2,3 and 6):

Plant # 1:

Well Capacity = well 1 = 368 gpm
Treatment Capacity (aerator) = 225 gpm
Clearwell Capacity = 11,500 gallons
Service Pump Capacity = 150 + 150 = 300 gpm
Usable Service Pump Capacity = Limiting Factor + Clearwell Volume / 200
= 225 + 11,500 / 200 = 283 gpm

Plant # 2:

Well Capacity = well 2 = 185 gpm
Treatment Capacity (aerator) = 450 gpm
Clearwell Capacity = 14,000 gallons
Service Pump Capacity = 450 gpm
Usable Service Pump Capacity = Limiting Factor + Clearwell Volume / 200
= 185 + 14,000 / 200 = 255 gpm

Plant # 3:

Well Capacity = well 3 = 385 gpm
Treatment Capacity (aerator) = 300 gpm
Clearwell Capacity = 9,200 gallons
Service Pump Capacity = 150 + 150 = 300 gpm
Usable Service Pump Capacity = Service Pumps are Limiting Factor = 300 gpm

Plant # 6:

Well Capacity = well 6 = 420 gpm
Treatment Capacity (aerator) = 500 gpm
Clearwell Capacity = 23,000 gallons
Service Pump Capacity = 350 + 350 = 700 gpm
Usable Service Pump Capacity = Limiting Factor + Clearwell Volume / 200
= 420 + 23,000 / 200 = 535 gpm

Main System Usable Service Pump Capacity = Plant #1 + Plant #2 + Plant #3 + Plant #6
= 283 + 255 + 300 + 535 = 1,373 gpm

Main System Elevated Storage = 75,000 + 100,000 = 175,000 gallons

Main System Design Capacity = 1,373 + 175,000 / 200 = 2,248 gpm

Number of Connections = 1,471

% Capacity = (Equivalent Connections / Design Capacity) * 100
= (1,471 / 2,248) * 100 = 65%

PLANT # 5 SYSTEM:

Well Capacity = well 5 = 283 gpm
Treatment Capacity (aerator) = 300 gpm
Clearwell Capacity = 12,000 gallons

**MISSISSIPPI DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
DESIGN CAPACITY SHEET**

SMITHS CROSSING WATER ASSN 11/04/2025

Service Pump Capacity = 200 + 200 = 400 gpm

Usable Service Pump Capacity = Limiting Factor + Clearwell Volume / 200
= 283 + 12,000 / 200 = 343 gpm

Design Capacity = Usable Service Pump Capacity + Elevated Storage / 200
= 343 + 75,000 / 200 = 718 gpm

Number of Connections = 181

% Capacity = (Equivalent Connections / Design Capacity) * 100
= (181 / 718) * 100 = 25%

WHOLE SYSTEM (Both systems combined):

Whole System Design Capacity = Main System + Plant # 5 System
= 2,248 + 718 = 3,966 gpm

Number of Connections = 1,652

% Capacity = (Equivalent Connections / Design Capacity) * 100
= (1,652 / 3,966) * 100 = 41.7%

Calculations for T15:

Largest Capacity Well = Well 06 = 420 gpm

Main System Pump Capacity without Well 06 = 283 + 255 + 300 = 838 gpm

Main System Design Capacity without Well 06 = 838 + 175,000 / 200 = 1,713 gpm

Whole System Design Capacity = 1,713 + 718 = 2,431 gpm

% Capacity without Well 06 = (1,652 / 2,431) * 100 = 68%

Therefore, the System receives credit for T15.